

## WATER CHLORINE SAMPLING FORM

Sample collection details

Collected by: Brian Young

Collection date: 22 October 2020

Collection time: 09:00 / 11:15

Collected on behalf of: **Connect Saint Helena Ltd**

Tests Requested:     Chlorine levels  
(Please tick)

Ref No	Source/Site	Macroscopic Appearance	Chlorine Levels	
			Free	Total
CSH002/1	Standpipe Nr McDaniel's Shop, Cleughs Plain	Clear	1.83	2.10
CSH002/2	Standpipe Bellstone, Levelwood	Clear	2.24	2.50
CSH002/3	Standpipe Nr Foxes Garage, Deadwood	Clear	1.77	1.99
CSH002/4	Standpipe Nr Museum, Jamestown	Clear	1.70	1.93

### FOR OFFICE USE

Received by

Name: Paul Duncan

Title: Water Operations Manager

Signature:  \_\_\_\_\_

Date received: 22 October 2020

