

## WATER CHLORINE SAMPLING FORM

Sample collection details

Collected by: Brian Young

Collection date: 26 October 2020

Collection time: 10:40 / 12:50

Collected on behalf of: **Connect Saint Helena Ltd**

Tests Requested:     Chlorine levels  
(Please tick)

Ref No	Source/Site	Macroscopic Appearance	Chlorine Levels	
			Free	Total
CSH003/1	Standpipe Cow Path Tank	Clear	1.79	2.12
CSH003/2	Standpipe Nr Sheltered Accommodation, Levelwood	Clear	3.16	3.65
CSH003/3	Standpipe Nr Reggie's Takeaway, Bottom Woods	Clear	2.09	2.42
CSH003/4	Standpipe Playground, Jamestown	Clear	1.07	1.22

### FOR OFFICE USE

Received by

Name: Paul Duncan

Title: Water Operations Manager

Signature:  \_\_\_\_\_

Date received: 26 October 2020

