

Sample type: Swimming Pool

Routine Control Mains – Cl

<mark>Mains – Chlorinated</mark>

Mains – Untreated

Other (Specify)

Sample collection details: Collected by: Terri Clingham Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 13/01/2020

Sample receipt details: Date Received in Lab: 13/01/2020

*Testing Date:* 13/01/2020-16/01/2020

		*	* Cl. Levels (ppm)		Microbiology Results					
Lab No.	Source/Site	Macroscopi								
		с			* WM 004		WM 002		WM 003	
		Appearance			Total Colony Count					
					cfu/1ml					
							Coliforms	E.coli	Enterococci	
			Free	Total	22°C/72h	37°C/48h	cfu/100 ml	cfu/100 ml	cfu/100ml	
W0004/1	Nr Sheltered Accommodation Level wood- Stand Pipe	Clear	1.16	1.41	32	88	Not Detected	Not Detected	Not Detected	
W0004/2	Nr Reggies Takeaway Longwood- Stand Pipe	Clear	2.30	2.65	0	3	Not Detected	Not Detected	Not Detected	
W0004/3	Cow Path Tank HTH Stand Pipe	Clear	1.90	2.25	5	60	Not Detected	Not Detected	Not Detected	
W0004/4	Playground – Jamestown Stand Pipe	Clear	1.88	2.36	2	1	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units

NE – Not examined

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	(KDayeto	Date:	16/01/2020
Checked by Trainee Quality Manager:	Keira Francis	Signature:	Hore	Date:	16/01/2020
Authorized by Lab Manager:	Geoff Benjamin	Signature:	Startan	Date:	16/01/2020

Notes:

1. Tests marked with \* are NOT UKAS accredited

2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

3. These results relate **ONLY** to the samples as received and tested..

4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.

5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.