

## ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @sainthelena.gov.sh

## WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0034/20

4564

Mains – Chlorinated Sample type: Swimming Pool Routine Control

Mains – Untreated

Other (Specify)

Sample collection details: Collected by: Anthony Peters Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 11/05/2020

Sample receipt details: Date Received in Lab: 11/05/2020 *Testing Date:* 12/05/2020-15/05/2020

		*	* Cl. Levels (ppm)		Microbiology Results					
Lab No.	Source/Site	Macroscopic								
		Appearance			* WM 004		WM 002		WM 003	
					Total Colony Count					
					cfu/1ml					
							Coliforms	E.coli	Enterococci	
			Free	Total	22°C/72h	37°C/48h	cfu/100 ml	cfu/100 ml	cfu/100ml	
W0034/1	Standpipe Bell Stone	Clear	1.20	1.42	0	5	Not Detected	Not Detected	Not Detected	
W0034/2	Standpipe Foxes Garage	Clear	1.92	2.22	0	0	Not Detected	Not Detected	Not Detected	
W0034/3	Standpipe McDaniel Shop	Clear	1.05	1.19	>300	>300	Not Detected	Not Detected	Not Detected	
W0034/4	Standpipe Museum	Clear	2.43	2.95	1	0	Not Detected	Not Detected	Not Detected	

**KEY:** cfu – colony forming units

NE - Not examined

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayeto	Date:	15/05/2020
Checked by Quality Manager:	Keira Francis	Signature:	Horse	Date:	15/05/2020
Authorized by Lab Manager:	Geoff Benjamin	Signature:	(July	Date:	15/05/2020

## Notes:

- 1. Tests marked with \* are **NOT** UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.