

Sample type: Swimming Pool

<mark>Mains – Chlorinated</mark>

<mark>ited</mark> Mains – Untreated

Other (Specify)

Sample collection details: Collected by: Darren Isaac

Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 29/06/2020

Sample receipt details: Date Received in Lab: 29/06/2020

Routine Control

Testing Date: 29/06/2020-02/07/2020

Lab No.	Source/Site	* Macroscopic		Levels om)	Microbiology Results					
		Appearance			* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003	
			Free	Total	22ºC/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml	
W0046/1	Standpipe Cow Path Tank	Clear	2.11	2.29	1	0	Not Detected	Not Detected	Not Detected	
W0046/2	Standpipe Nr. Sheltered Accommodation, Levelwood	Clear	1.04	1.17	0	1	Not Detected	Not Detected	Not Detected	
W0046/3	Standpipe Nr. Reggies Takeaway, Bottom Woods	Clear	1.87	2.03	9	18	Not Detected	Not Detected	Not Detected	
W0046/4	Standpipe Playground Jamestown	Clear	1.11	1.25	0	1	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units

NE – Not examined

Reported by Ag Food Microbiologist:	Keira Francis	Signature:	Harce	Date:	06/07/2020
Checked by Ag Quality Manager:	Geoffrey Benjamin	Signature:	KDaydo	Date:	06/07/2020
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:	Butur	Date:	06/07/2020

Notes:

1. Tests marked with * are NOT UKAS accredited

2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

3. These results relate **ONLY** to the samples as received and tested.

4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.

5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.