



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: microbiology@sainthelena.gov.sh

**WATER MICROBIOLOGY TEST REPORT**

REPORT NUMBER: 0066/20



Sample type: *Swimming Pool*      *Routine Control*      **Mains – Chlorinated**      *Mains – Untreated*      *Other (Specify)*

Sample collection details: *Collected by: Darren Isaac*      *Name & Address of Customer: Connect St Helena, Seales Corner*      *Collection date: 17/08/2020*

Sample receipt details: *Date Received in Lab: 17/08/2020*      *Testing Date: 18/08/2020-21/08/2020*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1 ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W0063/1	Standpipe Three Tanks	Clear	1.33	1.47	1	0	Not Detected	Not Detected	Not Detected
W0063/2	Standpipe Nr Longwood Clinic	Clear	2.05	2.33	0	1	Not Detected	Not Detected	Not Detected
W0063/3	Contact Tank Hutts Gate	Clear	2.28	2.63	0	1	Not Detected	Not Detected	Not Detected
W0063/4	Standpipe Dillon's Tank Jamestown	Clear	1.13	1.28	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Ag. Food Microbiologist:	Keira Francis	Signature:		Date:	24/08/2020
Checked by Ag. Quality Manager:	Wiseman Mbatha	Signature:		Date:	24/08/2020
Authorized by Ag. Lab Manager:	Wiseman Mbatha	Signature:		Date:	24/08/2020

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
3. These results relate **ONLY** to the samples as received and tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.