

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0068/20



Sample type: Swimming Pool Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 24/08/2020

		*	* Cl. 1	* Cl. Levels		Microbiology Results				
Lab No.	Source/Site	Macroscopic	(ppm)							
		Appearance			* WM 004		WM 002		WM 003	
					Total Colony Count					
					cfu/1 ml					
							Coliforms	E.coli	Enterococci	
			Free	Total	22°C/72h	37°C/48h	cfu/100 ml	cfu/100 ml	cfu/100ml	
W0064/1	Standpipe Spring Gut	Clear	1.79	2.01	0	0	Not Detected	Not Detected	Not Detected	
W0064/2	Tank Nr Kingdom Hall	Clear	1.09	1.26	0	0	Not Detected	Not Detected	Not Detected	
W0064/3	Standpipe Nr David Benjamins Two Gun Saddle	Clear	1.81	2.18	0	0	Not Detected	Not Detected	Not Detected	
W0064/4	Standpipe Nr Haytown Ruperts	Clear	1.72	2.10	3	5	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units

NE – Not examined

Reported by Ag. Food Microbiologist:	Keira Francis	Signature:	Hance	Date:	28/08/2020
Checked by Ag. Quality Manager:	Wiseman Mbatha	Signature:	(utmbertue);	Date:	28/08/2020
Authorized by Ag. Lab Manager:	Wiseman Mbatha	Signature:	untitactus.	Date:	28/08/2020

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.