



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: microbiology @ sainthelena.gov.sh

**WATER MICROBIOLOGY TEST REPORT**

REPORT NUMBER: 0025/24  
 ISSUE DATE: 15/03/24



Sample type: *Swimming Pool*    *Routine Control*    **Mains – Chlorinated**    *Mains – Untreated*    *Other (Specify)*

Sample collection details: *Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seals Corner Collection Date: 12/03/2024*

Sample receipt details: *Date Received in Lab: 12/03/2024*

*Testing Date: 12/03/2024– 15/03/2024*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W025/1	Nr Levelwood Clinic	Clear	2.10	2.34	0	0	Not Detected	Not Detected	Not Detected
W025/2	Hutt's Gate Contact Tank	Clear	3.74	3.99	0	0	Not Detected	Not Detected	Not Detected
W025/3	3 Tanks HTH	Clear	1.03	1.21	>300	>300	Not Detected	Not Detected	Not Detected
W025/4	Dillon's Tank Jamestown	Clear	1.41	1.62	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

<b>Reported by Food Microbiologist:</b>	<b>Kudzaiishe Nayoto</b>	<b>Signature:</b>		<b>Date:</b>	15/03/2024
<b>Checked by Ag Quality Manager:</b>	<b>Geoffrey Benjamin</b>	<b>Signature:</b>		<b>Date:</b>	15/03/2024
<b>Authorized by Lab Manager:</b>	<b>Geoffrey Benjamin</b>	<b>Signature:</b>		<b>Date:</b>	15/03/2024

Notes:



**ST HELENA PUBLIC HEALTH LABORATORY**  
General Hospital, Jamestown, St Helena  
Tel: +290 22500 Ext. 2035 Fax: +290 22530  
E-mail: microbiology @ sainthelena.gov.sh

## WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0025/24  
ISSUE DATE: 15/03/24



4564

1. Tests marked with \* are **NOT** UKAS accredited
2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
3. These results relate **ONLY** to the samples as received and tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.