



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0035/23
ISSUE DATE: 12/05/2023



Sample type: *Swimming Pool* *Routine Control* **Mains – Chlorinated** *Mains – Untreated* *Other (Specify)*

Sample collection details: *Collected by: Darren Isaac* *Name & Address of Customer: Connect St Helena, Seales Corner* *Collection date: 09/05/2023*

Sample receipt details: *Date Received in Lab: 09/05/2023* *Testing Date: 09/05/2023–12/05/2023*

| Lab No. | Source/Site | * Macroscopic Appearance | * Cl. Levels (ppm) | | Microbiology Results | | | | |
|---------|--------------------------|--------------------------|--------------------|-------|---|----------|-------------------------|----------------------|--|
| | | | Free | Total | * WM 004 Total Colony Count cfu/1ml | | WM 002 | | WM 003 Enterococci cfu/100ml |
| | | | | | 22°C/72h | 37°C/48h | Coliforms cfu/100 ml | E.coli cfu/100 ml | |
| W032/1 | Levelwood Contact Tank | Clear | 2.81 | 3.03 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W032/2 | Nr Longwood Clinic | Clear | 2.34 | 2.61 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W032/3 | Chubbspring Contact Tank | Clear | 2.71 | 2.99 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W032/4 | Red Hill Contact Tank | Clear | 3.02 | 3.36 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W032/5 | Bellstone Levelwood | Clear | 1.27 | 1.41 | 0 | 2 | Not Detected | Not Detected | Not Detected |
| W032/6 | Nr Fox's Garage Deadwood | Clear | 1.34 | 1.74 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W032/7 | Nr Cleughs Plain Shop | Clear | 1.33 | 1.71 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W032/8 | Nr Museum Jamestown | Clear | 1.26 | 1.59 | 0 | 2 | Not Detected | Not Detected | Not Detected |

KEY: cfu – colony forming units
 NE – Not examined

| | | | | | |
|--|----------------|-------------------|--|--------------|------------|
| Reported by Ag Food Microbiologist: | Toni Joshua | Signature: | | Date: | 12/05/2023 |
| Checked by Ag Quality Manager: | Wiseman Mbatha | Signature: | | Date: | 12/05/2023 |




ST HELENA PUBLIC HEALTH LABORATORY
General Hospital, Jamestown, St Helena
Tel: +290 22500 Ext. 2035 Fax: +290 22530
E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0035/23
ISSUE DATE: 12/05/2023



| | | | | | |
|--------------------------------------|----------------|-------------------|---|--------------|------------|
| Authorized by Ag Lab Manager: | Wiseman Mbatha | Signature: |  | Date: | 12/05/2023 |
|--------------------------------------|----------------|-------------------|---|--------------|------------|

Notes:

1. Tests marked with * are NOT UKAS accredited
2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
3. These results relate **ONLY** to the samples as received and tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.