



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: 00290 2500 Ext. 304 Fax: 00290 2530  
 E-mail: [sf.microbiologist@publichealth.gov.sh](mailto:sf.microbiologist@publichealth.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



Sample type: *Swimming Pool*      *Routine Control*      **Mains – Chlorinated**      *Mains – Untreated*      *Other (Specify)*

Sample collection details: *Collected by: Colin Peters*      *Name & Address of Customer: Connect St Helena, Seales Corner*      *Collection date: 25/04/16*

Sample receipt details: *Date Received in Lab: 25/04/16*      *Testing Date: 25/04/16*

| Lab No. | Source/Site                                  | * Macroscopic Appearance | * Cl. Levels (ppm) |       | Microbiology Results                      |          |                         |                             |                                 |
|---------|--|--------------------------|--------------------|-------|---|----------|-------------------------|-----------------------------|---------------------------------|
|         |  |                          | Free               | Total | * WM 004<br>Total Colony Count<br>cfu/1ml |          | WM 002                  |                             | WM 003                          |
|         |  |                          |                    |       | 22°C/72h                                  | 37°C/48h | Coliforms<br>cfu/100 ml | <i>E.coli</i><br>cfu/100 ml | <i>Enterococci</i><br>cfu/100ml |
| W658/1  | Cowpath Tank                                 | Clear                    | 2.02               | 2.37  | 0   | 20       | Not Detected            | Not Detected                | Not Detected                    |
| W658/2  | Standpipe Nr Sawmill Scotland                | Clear                    | 1.22               | 1.55  | 0   | 0        | Not Detected            | Not Detected                | Not Detected                    |
| W658/3  | Contact Tank Levelwood                       | Clear                    | 2.49               | 2.84  | 0   | 0        | Not Detected            | Not Detected                | Not Detected                    |
| W658/4  | Standpipe Nr Sheltered Acc Levelwood Redhill | Clear                    | 1.59               | 2.03  | 7   | 19       | Not Detected            | Not Detected                | Not Detected                    |
| W658/5  | Standpipe Nr Reggies Takeaways Bottom Woods  | Clear                    | 2.09               | 2.20  | 0   | 0        | Not Detected            | Not Detected                | Not Detected                    |
| W658/6  | Standpipe Nr Golfcourse Longwood             | Clear                    | 2.54               | 2.72  | 0   | 0        | Not Detected            | Not Detected                | Not Detected                    |
| W658/7  | Briars Tank                                  | Clear                    | 1.28               | 1.41  | 44  | 39       | Not Detected            | Not Detected                | Not Detected                    |
| W658/8  | Standpipe Nr Market Jamestown                | Clear                    | 1.24               | 1.37  | 11  | 20       | Not Detected            | Not Detected                | Not Detected                    |

KEY: cfu – colony forming units  
 NE – Not examined

|   |                |                   |  |              |             |
|---|----------------|-------------------|--|--------------|-------------|
| <b>Reported by Food Microbiologist:</b> | Gift T Sibanda | <b>Signature:</b> |  | <b>Date:</b> | 28.04.2016  |
| <b>Checked by Quality Manger:</b>       | Helena Stevens | <b>Signature:</b> |  | <b>Date:</b> | 28/04/2016. |
| <b>Authorized by Lab Manager:</b>       | Geoff Benjamin | <b>Signature:</b> |  | <b>Date:</b> | 28.04.2016  |

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. For method WM 002, Lactose broth was used for confirmation, instead of Lactose Peptone Water broth.
5. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
6. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.