



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: 00290 2500 Ext. 304 Fax: 00290 2530  
 E-mail: [sf.microbiologist@publichealth.gov.sh](mailto:sf.microbiologist@publichealth.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



4564

Sample type: *Swimming Pool*    *Routine Control*    **Mains – Chlorinated**    *Mains – Untreated*    *Other (Specify)*

Sample collection details: *Collected by: Colin Peters*    *Name & Address of Customer: Connect St Helena, Seales Corner*    *Collection date: 26/09/16*

Sample receipt details: *Date Received in Lab: 26/09/16*    *Testing Date: 26/09/16*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W697/1	3 Tanks	Clear	2.57	2.83	87	109	Not Detected	Not Detected	Not Detected
W697/2	Standpipe Nr Playground HTH	Clear	2.39	2.72	0	0	Not Detected	Not Detected	Not Detected
W697/3	Cowpath Tank HTH	Clear	1.80	1.97	81	94	Not Detected	Not Detected	Not Detected
W697/4	Standpipe Nr Sawmill Scotland	Clear	2.54	2.76	0	0	Not Detected	Not Detected	Not Detected
W697/5	Contact Tank Redhill	Clear	3.70	3.88	30	43	Not Detected	Not Detected	Not Detected
W697/6	Standpipe Nr Solomons Shop Levelwood	Clear	1.91	2.14	0	0	Not Detected	Not Detected	Not Detected
W697/7	Standpipe Nr Clinic Levelwood	Clear	2.05	2.21	0	0	Not Detected	Not Detected	Not Detected
W697/8	Sheltered Acc Redhill Levelwood	Clear	1.96	2.15	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Food Microbiologist:	Gift T. Sibanda	Signature:		Date:	29.09.2016
Checked by Acting Quality Manger:	Geoff Benjamin	Signature:		Date:	29.09.2016
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	29.09.2016

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. For method WM 002, Lactose broth was used for confirmation, instead of Lactose Peptone Water broth.
5. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
6. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.