

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena

Tel: +290 2500 Ext. 2035 Fax: +290 2530

E-mail: sf.microbiologist@publichealth.gov.sh





Sample type: Swimming Pool

Routine Control

Mains - Chlorinated

Mains - Untreated

Other (Specify)

Sample collection details: Collected by: Colin Peters Name & Address of Customer: Connect St Helena, Seales Corner

Collection date: 27/10/16

Sample receipt details: Date Received in Lab: 27/10/16

Testing Date: 27/10/16

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
Lab No.			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml
W707/1	Contact Tank Levelwood	Clear	2.05	2.41	0	0	Not Detected	Not Detected	Not Detected
W707/2	Tank Nr Kingdom Hall Levelwood	Clear	1.92	2.15	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu - colony forming units

NE - Not examined

			(0)		
Reported by Food Microbiologist:	Gift T. Sibanda	Signature:		Date:	31.10.2016
Checked by Quality Manger:	Helena Stevens	Signature:	ABtevens	Date:	31/10/2015
Authorized by Lab Manager:	Geoff Benjamin	Signature:	ash her	Date:	31.10.2016

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples tested.
- 4. For method WM 002, Lactose broth was used for confirmation, instead of Lactose Peptone Water broth.
- 5. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
- 6. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.