

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 2500 Ext. 2035 Fax: +290 2530

E-mail: sf.microbiologist@publichealth.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: Swimming Pool

Routine Control

Mains - Chlorinated

Mains - Untreated

Other (Specify)

Sample collection details: Collected by: Colin Peters Name & Address of Customer: Connect St Helena, Seales Corner

Collection date: 16/01/17

Sample receipt details: Date Received in Lab: 16/01/17

Testing Date: 16/01/17

		*	* Cl. Levels (ppm)		Microbiology Results				
Lab No.	Source/Site	Macroscopic							
		Appearance			* WM 004		WM 002		WM 003
					Total Col	ony Count			
	p 2		Free	Total	cfu/1ml				
						_	Coliforms	E.coli	Enterococci
					22°C/72h	37°C/48h	cfu/100 ml	cfu/100 ml	cfu/100ml
W733/1	Standpipe Nr McDaniel Shop Cleughs Plain	Clear	1.13	1.21	39	51	Not Detected	Not Detected	Not Detected
W733/2	Standpipe Spring Gut	Clear	1.19	1.31	0	0	Not Detected	Not Detected	Not Detected
W733/3	Contact Tank Levelwood	Clear	1.80	2.36	0	0	Not Detected	Not Detected	Not Detected
W733/4	Standpipe Nr Kingdom Hall Levelwood	Clear	1.46	1.76	0	0	Not Detected	Not Detected	Not Detected
W733/5	Standpipe Nr Reggies Takeaways Bottomwoods	Clear	1.65	1.95	0	0	Not Detected	Not Detected	Not Detected
W733/6	Standpipe Nr Golf course Longwood	Clear	1.77	2.07	44	69	Not Detected	Not Detected	Not Detected
W733/7	Standpipe Nr Haytown Ruperts	Clear	2.30	2.46	0	0	Not Detected	Not Detected	Not Detected
W733/8	Nr Museum Jamestown	Clear	2.26	2.43	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu - colony forming units

NE - Not examined

Reported by Food Microbiologist:	Gift T. Sibanda	Signature:		Date: 19.01.2017
Checked by Quality Manger:	Helena Stevens	Signature:	ablavens.	Date: 19/01/2017.
Authorized by Lab Manager:	Geoff Benjamin	Signature:	Ster/ Bun	Date: 19.01/2017-

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples tested.
- 4. For method WM 002, Lactose broth was used for confirmation, instead of Lactose Peptone Water broth.
- 5. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
- 6. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.