



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 2500 Ext. 2035 Fax: +290 2530  
 E-mail: [sf.microbiologist@publichealth.gov.sh](mailto:sf.microbiologist@publichealth.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



Sample type: *Swimming Pool*      *Routine Control*      **Mains – Chlorinated**      *Mains – Untreated*      *Other (Specify)*

Sample collection details: *Collected by:* Colin Peters      *Name & Address of Customer:* Connect St Helena, Seales Corner      *Collection date:* 10/04/2017

Sample receipt details: *Date Received in Lab:* 10/04/17      *Testing Date:* 10/04/17

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W761/1	Standpipe Nr. Mc Daniel's Shop Cleughs Plain	Clear	3.12	3.62	0	0	Not Detected	Not Detected	Not Detected
W761/2	Standpipe Spring Gut	Clear	3.20	3.66	0	0	Not Detected	Not Detected	Not Detected
W761/3	Standpipe Bellstone Levelwood	Sl.Discoloured	1.83	2.25	0	0	Not Detected	Not Detected	Not Detected
W761/4	Nr. Kingdom Hall Levelwood	Sl.Discoloured	2.30	2.62	0	0	Not Detected	Not Detected	Not Detected
W761/5	Standpipe Nr. Fox Garage Deadwood	Clear	3.50	3.62	0	0	Not Detected	Not Detected	Not Detected
W761/6	Standpipe Nr. David Benjamin's Two Gun Saddle	Clear	3.41	3.63	0	0	Not Detected	Not Detected	Not Detected
W761/7	Standpipe Nr. Haytown Ruperts	Clear	2.57	2.64	0	0	Not Detected	Not Detected	Not Detected
W761/8	Standpipe Nr. Museum	Clear	1.13	1.24	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Ag. Food Microbiologist:	Helena Stevens	Signature:		Date:	13/04/2017
Checked by Ag. Quality Manager:	Geoff Benjamin	Signature:		Date:	13.04.2017
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	13.04.2017

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. For method WM 002, Lactose broth was used for confirmation, instead of Lactose Peptone Water broth.
5. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
6. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.