



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: [sf.microbiologist@publichealth.gov.sh](mailto:sf.microbiologist@publichealth.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



Sample type: *Swimming Pool*      *Routine Control*      **Mains – Chlorinated**      *Mains – Untreated*      *Other (Specify)*

Sample collection details: *Collected by:* Colin Peters    *Name & Address of Customer:* Connect St Helena, Seales Corner      *Collection date:* 09/10/2017

Sample receipt details: *Date Received in Lab:* 09/10/2017      *Testing Date:* 09/10/2017

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W809/1	3 Tanks HTH	Clear	2.20	2.39	0	0	Not Detected	Not Detected	Not Detected
W809/2	Standpipe Nr Playground HTH	Clear	1.97	2.18	0	0	Not Detected	Not Detected	Not Detected
W809/3	Contact Tank Redhill	Clear	2.67	2.83	0	0	Not Detected	Not Detected	Not Detected
W809/4	Standpipe Nr Clinic Levelwood	Clear	2.10	2.32	0	0	Not Detected	Not Detected	Not Detected
W809/5	Contact Tank Hutts Gate	Clear	2.91	3.13	0	0	Not Detected	Not Detected	Not Detected
W809/6	Standpipe Nr Clinic Longwood	Clear	2.69	2.82	0	0	Not Detected	Not Detected	Not Detected
W809/7	Contact Tank Chubb Spring	Clear	3.46	3.60	0	0	Not Detected	Not Detected	Not Detected
W809/8	Dillon's Tank Jamestown	Clear	2.80	2.92	0	0	Not Detected	Not Detected	Not Detected

**KEY: cfu – colony forming units\***  
 NE – Not examined

<b>Reported by Food Microbiologist:</b>	Gift T. Sibanda	<b>Signature:</b>		<b>Date:</b>	12.10.2017
<b>Checked by Acting Quality Manager:</b>	Geoff Benjamin	<b>Signature:</b>		<b>Date:</b>	12.10.2017
<b>Authorized by Lab Manager:</b>	Geoff Benjamin	<b>Signature:</b>		<b>Date:</b>	12.10.2017

- Notes:
1. Tests marked with \* are NOT UKAS accredited
  2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
  3. These results relate **ONLY** to the samples tested.
  4. For method WM 002, Lactose broth was used for confirmation, instead of Lactose Peptone Water broth.
  5. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
  6. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.