

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530

E-mail: gift.sibanda@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: Swimming Pool

Routine Control

Mains - Chlorinated

Mains - Untreated

Other (Specify)

Sample collection details: Collected by: Brian Young Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 10/09/2018

Sample receipt details: Date Received in Lab: 10/09/2018

Testing Date: 10/09/2018

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
		Appearance	Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml
W907/1	Standpipe Cow Path Tank	Clear	1.82	2.06	0	0	Not Detected	Not Detected	Not Detected
W907/2	Standpipe Nr Sawmill	Clear	1.90	2.12	0	0	Not Detected	Not Detected	Not Detected
W907/3	Standpipe Nr Solomon Shop Levelwood	Clear	2.97	3.30	0	0	Not Detected	Not Detected	Not Detected
W907/4	Standpipe Redhill Levelwood	Clear	2.31	2.60	0	0	Not Detected	Not Detected	Not Detected
W907/5	Standpipe Nr Golf Course Longwood	Clear	3.89	4.26	0	0	Not Detected	Not Detected	Not Detected
W907/6	Standpipe Nr Reggie's Takeaway	Clear	3.75	3.90	0	0	Not Detected	Not Detected	Not Detected
W907/7	Standpipe Briars Tank	Clear	2.19	2.49	0	0	Not Detected	Not Detected	Not Detected
W907/8	Standpipe Market Street Jamestown	Clear	1.39	1.71	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu - colony forming units

NE - Not examined

			COVA (V)	- 1 1 63
Reported by Food Microbiologist:	Gift T. Sibanda	Signature:	Defail sa	Date: 13/09 20 18
Checked by Acting Quality Manager:	Geoff Benjamin	Signature:	Sector lum	Date: 14.69.2018
Authorized by Lab Manager:	Geoff Benjamin	Signature:	Kichilan "	Date: 14.09.2018

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate ONLY to the samples tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.