



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: [gift.sibanda@sainthelena.gov.sh](mailto:gift.sibanda@sainthelena.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



4564

Sample type: *Swimming Pool*      *Routine Control*      **Mains – Chlorinated**      *Mains – Untreated*      *Other (Specify)*

Sample collection details: *Collected by:* Brian Young    *Name & Address of Customer:* Connect St Helena, Seales    *Corner Collection date:* 17/09/2018

Sample receipt details: *Date Received in Lab:* 17/09/2018      *Testing Date:* 17/09/2018

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003 <i>Enterococci</i> cfu/100ml
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	
W909/1	Standpipe Cleughs Plain	Clear	1.36	1.52	0	0	Not Detected	Not Detected	Not Detected
W909/2	Standpipe Spring Gut Tank	Clear	1.51	1.74	0	0	Not Detected	Not Detected	Not Detected
W909/3	Standpipe Bellstone	Clear	3.05	3.36	0	0	Not Detected	Not Detected	Not Detected
W909/4	Standpipe Kingdom Hall Levelwood	Clear	2.63	3.02	0	0	Not Detected	Not Detected	Not Detected
W909/5	Standpipe Fox Garage Deadwood	Clear	2.00	2.34	0	0	Not Detected	Not Detected	Not Detected
W909/6	Standpipe Two Gun Saddle	Clear	2.19	2.48	0	0	Not Detected	Not Detected	Not Detected
W909/7	Standpipe Ruperts	Clear	1.30	1.57	0	0	Not Detected	Not Detected	Not Detected
W909/8	Standpipe New Horizons	Clear	1.33	1.62	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Food Microbiologist:	Gift T. Sibanda	Signature:		Date:	20/09/2018
Checked by Quality Manager:	Helena Stevens	Signature:		Date:	20/09/2018
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	20.09/2018

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.