



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: gift.sibanda@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



4564

Sample type: *Swimming Pool* *Routine Control* ***Mains – Chlorinated*** *Mains – Untreated* *Other (Specify)*

Sample collection details: *Collected by: Brian Young* *Name & Address of Customer: Connect St Helena, Seales* *Corner* *Collection date: 22/10/2018*

Sample receipt details: *Date Received in Lab: 22/10/2018* *Testing Date: 22/10/2018*

| Lab No. | Source/Site | * Macroscopic Appearance | * Cl. Levels (ppm) | | Microbiology Results | | | | |
|---------|--------------------------------------|--------------------------|--------------------|-------|---|----------|-------------------------|-----------------------------|---------------------------------|
| | | | Free | Total | * WM 004 Total Colony Count cfu/1ml | | WM 002 | | WM 003 |
| | | | | | 22°C/72h | 37°C/48h | Coliforms cfu/100 ml | <i>E.coli</i> cfu/100 ml | <i>Enterococci</i> cfu/100ml |
| W917/1 | Standpipe Three Tanks | Clear | 2.25 | 2.58 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/2 | Standpipe HTH Playground | Clear | 1.72 | 2.06 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/3 | Standpipe Redhill Contact Tank | Clear | 3.27 | 3.49 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/4 | Standpipe Levelwood Clinic | Clear | 2.80 | 3.12 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/5 | Standpipe Hutts Gate Contact Tank | Clear | 3.82 | 4.08 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/6 | Standpipe Longwood Clinic | Clear | 3.22 | 3.55 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/7 | Standpipe Chubbs Spring Contact Tank | Clear | 2.84 | 3.17 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W917/8 | Standpipe Dillons Tank Jamestown | Clear | 1.49 | 1.84 | 2 | 3 | Not Detected | Not Detected | Not Detected |

KEY: cfu – colony forming units
 NE – Not examined

| | | | | | |
|----------------------------------|-----------------|------------|--|-------|------------|
| Reported by Food Microbiologist: | Gift T. Sibanda | Signature: | | Date: | 25.10.2018 |
| Checked by Quality Manager: | Helena Stevens | Signature: | | Date: | 25/10/2018 |
| Authorized by Lab Manager: | Geoff Benjamin | Signature: | | Date: | 25.10.2018 |

- Notes:
1. Tests marked with * are NOT UKAS accredited
 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
 3. These results relate ONLY to the samples tested.
 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.