



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: [gift.sibanda@sainthelena.gov.sh](mailto:gift.sibanda@sainthelena.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



**Sample type:** *Swimming Pool*     *Routine Control*     **Mains – Chlorinated**     *Mains – Untreated*     *Other (Specify)*

**Sample collection details:** *Collected by:* Colin Peters     *Name & Address of Customer:* Connect St Helena, Seales     *Corner Collection date:* 10/12/2018

**Sample receipt details:** *Date Received in Lab:* 10/12/2018     *Testing Date:* 10/12/2018

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
					* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml
W939/1	Standpipe Nr. Mc Daniel's Shop Cleughs Plain	Clear	1.05	1.25	0	0	Not Detected	Not Detected	Not Detected
W939/2	Standpipe Spring Gut	Clear	1.13	1.32	0	0	Not Detected	Not Detected	Not Detected
W939/3	Standpipe Nr. Bellstone Levelwood	Clear	1.52	1.70	0	0	Not Detected	Not Detected	Not Detected
W939/4	Standpipe Nr. Kingdom Hall Levelwood	Clear	1.60	1.80	0	0	Not Detected	Not Detected	Not Detected
W939/5	Standpipe Nr, Fox Garage Deadwood	Clear	1.38	1.65	0	0	Not Detected	Not Detected	Not Detected
W939/6	Standpipe Nr. David Benjamin's Two Gun Saddle	Clear	1.00	1.05	0	0	Not Detected	Not Detected	Not Detected
W939/7	Standpipe Nr. Haytown Ruperts	Clear	2.02	2.22	0	0	Not Detected	Not Detected	Not Detected
W939/8	Standpipe Nr. Museum Jamestown	Clear	1.91	2.20	0	0	Not Detected	Not Detected	Not Detected

**KEY:** cfu – colony forming units  
 NE – Not examined

<b>Reported by Ag. Food Microbiologist:</b>	Helena Stevens	<b>Signature:</b>		<b>Date:</b>	13/12/2018
<b>Checked by Ag. Quality Manager:</b>	Geoff Benjamin	<b>Signature:</b>		<b>Date:</b>	13.12.2018
<b>Authorized by Lab Manager:</b>	Geoff Benjamin	<b>Signature:</b>		<b>Date:</b>	13.12.2018

**Notes:**

1. Tests marked with \* are NOT UKAS accredited
2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
3. These results relate **ONLY** to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.