



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: microbiology@sainthelena.gov.sh

**WATER MICROBIOLOGY TEST REPORT**



Sample type: *Swimming Pool*    *Routine Control*    **Mains – Chlorinated**    *Mains – Untreated*    *Other (Specify)*

Sample collection details: *Collected by: Colin Peters*    *Name & Address of Customer: Connect St Helena, Seales*    *Corner*    *Collection date: 25/02/2019*

Sample receipt details: *Date Received in Lab: 25/02/2019*    *Testing Date: 25/02/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
					* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W953/1	Cow Path Tank H.T.H.	Clear	1.15	1.51	0	0	Not Detected	Not Detected	Not Detected
W953/2	Standpipe Nr. Sawmill Scotland	Clear	0.97	1.04	0	0	Not Detected	Not Detected	Not Detected
W953/3	Standpipe Nr. Solomons Shop Levelwood	Clear	1.71	1.91	0	0	Not Detected	Not Detected	Not Detected
W953/4	Standpipe Nr. Sheltered Acc. Red Hill Levelwood	Clear	1.31	1.43	0	0	Not Detected	Not Detected	Not Detected
W953/5	Standpipe Nr. Reggie's Takeaways Bottom Woods	Clear	0.94	1.02	0	0	Not Detected	Not Detected	Not Detected
W953/6	Standpipe Nr. Golf Course Longwood	Clear	0.97	1.06	0	0	Not Detected	Not Detected	Not Detected
W953/7	Briars Tank	Clear	2.09	2.20	0	0	Not Detected	Not Detected	Not Detected
W953/8	Standpipe Playground Jamestown	Clear	1.82	1.96	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Ag. Food Microbiologist:	Helena Stevens	Signature:		Date:	28/02/2019
Checked by Ag. Quality Manager:	Geoff Benjamin	Signature:		Date:	28.02.19
Authorized by Ag. Lab Manager:	Geoff Benjamin	Signature:		Date:	28.02.19

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.