



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: *Swimming Pool* *Routine Control* **Mains – Chlorinated** *Mains – Untreated* *Other (Specify)*

Sample collection details: *Collected by: Colin Peters* *Name & Address of Customer: Connect St Helena, Seales* *Corner Collection date: 18/03/2019*

Sample receipt details: *Date Received in Lab: 18/03/2019* *Testing Date: 18/03/2019*

| Lab No. | Source/Site | * Macroscopic Appearance | * Cl. Levels (ppm) | | Microbiology Results | | | | |
|---------|---|--------------------------|--------------------|------|-------------------------------------|----------|----------------------|-------------------|-----------------------|
| | | | | | * WM 004 Total Colony Count cfu/1ml | | WM 002 | | WM 003 |
| | | | | | 22°C/72h | 37°C/48h | Coliforms cfu/100 ml | E.coli cfu/100 ml | Enterococci cfu/100ml |
| W958/1 | Standpipe Cow Path H.T.H. | Clear | 1.30 | 1.67 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W958/2 | Standpipe Nr. Sawmill Scotland | Clear | 1.07 | 1.13 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W958/3 | Standpipe Nr. Solomons Shop Leve;wood | Clear | 1.62 | 1.82 | 7 | 12 | Not Detected | Not Detected | Not Detected |
| W958/4 | Standpipe Nr. Sheltered Acc. Red Hill Levelwood | Clear | 1.18 | 1.48 | 9 | 8 | Not Detected | Not Detected | Not Detected |
| W958/5 | Standpipe Nr. Reggie's Takeaway Bottom Woods | Clear | 0.93 | 1.02 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W958/6 | Standpipe Nr. Golf Course Longwood | Clear | 0.97 | 1.19 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W958/7 | Standpipe Briars Tank | Clear | 1.64 | 1.81 | 0 | 0 | Not Detected | Not Detected | Not Detected |
| W958/8 | Standpipe Playground Jamestown | Clear | 1.40 | 1.52 | 0 | 0 | Not Detected | Not Detected | Not Detected |

KEY: cfu – colony forming units
 NE – Not examined

| | | | | | |
|--------------------------------------|----------------|------------|--|-------|------------|
| Reported by Ag. Food Microbiologist: | Helena Stevens | Signature: | | Date: | 21/03/2019 |
| Checked by Ag. Quality Manager: | Geoff Benjamin | Signature: | | Date: | 21.03.2019 |
| Authorized by Ag. Lab Manager: | Geoff Benjamin | Signature: | | Date: | 21.03.2019 |

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.