



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



4564

Sample type: *Swimming Pool*

Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: *Collected by: Colin Peters Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 24/06/2019*

Sample receipt details: *Date Received in Lab: 24/06/2019*

Testing Date: 24/06/2019

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		* WM 004 Total Colony Count cfu/1ml				Microbiology Results			
			Free	Total	22°C/72h		37°C/48h		Coliforms cfu/100 ml	E. coli cfu/100 ml	WM 002	WM 003
					0	0	0	0				
W976/1	Standpipe Nr. Mc Daniel's Shop Cleugh's Plain	Clear	1.25	1.50	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/2	Kingdom Hall Tank Levelwood	Clear	2.24	2.41	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/3	Standpipe Nr. Bellstone Levelwood	Clear	1.82	1.91	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/4	Standpipe Nr. Fox Garage Deadwood	Clear	2.36	2.48	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/5	Standpipe Nr. David Benjamin's Two Gun Saddle	Clear	2.07	2.33	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/6	Standpipe Nr. Haytown Ruperts	Clear	2.30	2.42	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/7	Standpipe Nr. Spring Gut	Clear	1.94	2.16	0	0	0	0	Not Detected	Not Detected	Not Detected	
W976/8	Standpipe Nr. Museum Jamestown	Clear	2.25	2.41	0	0	0	0	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units
 NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	21/06/2019
Checked by Quality Manager:	Helena Stevens	Signature:		Date:	27/06/2019
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	27/06/2019

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.