



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



4564

Sample type: *Swimming Pool* Routine Control **Mains – Chlorinated** Mains – Untreated Other (Specify)

Sample collection details: *Collected by: Colin Peters* Name & Address of Customer: *Connect St Helena, Seales* Corner Collection date: *08/07/2019*

Sample receipt details: *Date Received in Lab: 08/07/2019* Testing Date: *08/07/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results			
			* WMM 004 Total Colony Count cfu/1ml		WMM 002	WMM 003		
			22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml	
W978/1	3 Tanks H.T.H.	Clear	1.08	1.18	0	0	Not Detected	Not Detected
W978/2	Standpipe Nr. Playground H.T.H.	Clear	1.01	1.11	0	0	Not Detected	Not Detected
W978/3	Contact Tank Red Hill	Clear	2.70	2.90	0	0	Not Detected	Not Detected
W978/4	Standpipe Nr. Clinic Levelwood	Clear	2.28	2.46	0	0	Not Detected	Not Detected
W978/5	Contact Tank Hurts Gate	Clear	2.59	2.70	0	0	Not Detected	Not Detected
W978/6	Standpipe Nr. Clinic Longwood	Clear	2.38	2.49	0	0	Not Detected	Not Detected
W978/7	Contact Tank Chubb Spring	Clear	2.82	2.96	0	0	Not Detected	Not Detected
W978/8	Dillon's Tank Jamestown	Clear	2.47	2.57	0	0	Not Detected	Not Detected

KEY: cfu – colony forming units
 NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	11/07/19
Checked by Quality Manager:	Helena Stevens	Signature:		Date:	11/07/19
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	11/07/19

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.