




ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: *Swimming Pool* Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: *Collected by: Colin Peters* Name & Address of Customer: *Connect St Helena, Seales* Corner Collection date: *15/07/2019*

Sample receipt details: *Date Received in Lab: 15/07/2019* Testing Date: *15/07/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)	* WM 004 Total Colony Count cfu/1ml			Microbiology Results		
				22°C/72h	37°C/48h	Coliforms cfu/100 ml	WMM 002 E. coli cfu/100 ml	WMM 003 Enterococci cfu/100ml	
W980/1	Standpipe Nr. Haytown Ruperts	Clear	2.09	0	0	Not Detected	Not Detected	Not Detected	
W980/2	Standpipe Nr. Mac Daniel's Shop Cleugh's Plain	Clear	1.19	0	0	Not Detected	Not Detected	Not Detected	
W980/3	Standpipe Spring Gut	Clear	1.24	0	0	Not Detected	Not Detected	Not Detected	
W980/4	Kingdom Hall Tank Levelwood.	Clear	2.50	0	0	Not Detected	Not Detected	Not Detected	
W980/5	Standpipe Nr. Bellstone Levelwood	Clear	2.59	0	0	Not Detected	Not Detected	Not Detected	
W980/6	Standpipe Nr. Fox Garage Deadwood	Clear	2.80	0	0	Not Detected	Not Detected	Not Detected	
W980/7	Standpipe Nr. David Benjamin's Two Gun Saddle	Clear	2.82	0	0	Not Detected	Not Detected	Not Detected	
W980/8	Standpipe Nr. Museum Jamestown	Clear	1.72	0	0	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units
 NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	18/07/19
Checked by Ag. Quality Manager:	Geoff Benjamin	Signature:		Date:	18/07/19
Authorized by Ag. Lab Manager:	Geoff Benjamin	Signature:		Date:	18/07/19

- Notes:
1. Tests marked with * are NOT UKAS accredited
 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
 3. These results relate ONLY to the samples tested.
 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.