



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



4564

Sample type: *Swimming Pool*

Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: *Collected by: Colin Peters Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 29/07/2019*

Sample receipt details: *Date Received in Lab: 29/07/2019*

Testing Date: 29/07/2019

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results			
			* W/M 004 Total Colony Count cfu/1ml	W/M 002		W/M 003 <i>Enterococci</i> cfu/100ml		
				<i>Coliforms</i> cfu/100 ml	<i>E. coli</i> cfu/100 ml			
W984/1	3 Tanks H.T.H.	Clear	0.92	1.02	0	0	Not Detected	Not Detected
W984/2	Standpipe Nr. Clinic Levelwood	Clear	2.40	2.56	0	0	Not Detected	Not Detected
W984/3	Contact Tank Hutts Gate	Clear	2.52	2.68	0	0	Not Detected	Not Detected
W984/4	Dillon's Tank Jamestown	Clear	2.48	2.58	0	0	Not Detected	Not Detected

KEY: cfu – colony forming units
 NE – Not examined

Reported by Food Microbiologist:	Kudzaitshie Nayoto	Signature:		Date:	01/08/19
Checked by Quality Manager:	Helena Stevens	Signature:		Date:	01/08/2019
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	01/08/2019

Notes:

1. Tests marked with * are NOT UKAS accredited
2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
3. These results relate **ONLY** to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.