



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: [microbiology@sainthelena.gov.sh](mailto:microbiology@sainthelena.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



4564

Sample type: *Swimming Pool*

*Routine Control*

**Mains – Chlorinated**

*Mains – Untreated*

*Other (Specify)*

Sample collection details: *Collected by: Brian Young Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 02/09/2019*

Sample receipt details: *Date Received in Lab: 02/09/2019*

*Testing Date: 02/09/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)			Microbiology Results			
			Free	Total	* W/M 004 Total Colony Count cfu/1ml		W/M 002		W/M 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E. coli</i> cfu/100 ml	
W/990/1	Standpipe Bellstone Levelwood	Clear	2.13	2.35	0	0	Not Detected	Not Detected	Not Detected
W/990/2	Standpipe McDaniels Shop Cleughs Plain	Clear	1.05	1.30	0	0	Not Detected	Not Detected	Not Detected
W/990/3	Standpipe Fox Garage Deadwood	Clear	2.34	2.49	0	0	Not Detected	Not Detected	Not Detected
W/990/4	Standpipe Museum Jamestown	Clear	2.25	2.32	0	0	Not Detected	Not Detected	Not Detected

**KEY: cfu – colony forming units**

**NE – Not examined**

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	06/09/19
Checked by Ag Quality Manager:	Geoff Benjamin	Signature:		Date:	06/09/19
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	06/09/19

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.