



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: microbiology@sainthelena.gov.sh

**WATER MICROBIOLOGY TEST REPORT**



**Sample type:** *Swimming Pool*    *Routine Control*    **Mains – Chlorinated**    *Mains – Untreated*    *Other (Specify)*

**Sample collection details:** *Collected by: Colin Peters Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 04/03/2019*

**Sample receipt details:** *Date Received in Lab: 04/03/2019 Testing Date: 04/03/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
					* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml
W955/1	3 Tanks H.T.H.	Clear	0.94	1.00	0	0	Not Detected	Not Detected	Not Detected
W955/2	Contact Tank Red Hill	Clear	2.54	2.97	0	0	Not Detected	Not Detected	Not Detected
W955/3	Standpipe Nr. Clinic Levelwood	Clear	2.02	2.11	0	0	Not Detected	Not Detected	Not Detected
W955/4	Contact Tank Hutts Gate	Clear	2.96	3.07	0	0	Not Detected	Not Detected	Not Detected
W955/5	Standpipe Nr. Clinic Longwood	Clear	1.87	1.98	0	0	Not Detected	Not Detected	Not Detected
W955/6	Standpipe Nr. White Wall H.T.H.	Clear	0.96	1.05	0	0	Not Detected	Not Detected	Not Detected
W955/7	Contact Tank Chubbs Spring	Clear	2.31	2.38	0	0	Not Detected	Not Detected	Not Detected
W955/8	Dillon's Tank Jamestown	Clear	2.16	2.20	0	0	Not Detected	Not Detected	Not Detected

**KEY:** cfu – colony forming units  
 NE – Not examined

<b>Reported by Ag. Food Microbiologist:</b>	Helena Stevens	<b>Signature:</b>		<b>Date:</b>	07/03/2019
<b>Checked by Ag. Quality Manager:</b>	Geoff Benjamin	<b>Signature:</b>		<b>Date:</b>	07.03.2019
<b>Authorized by Ag. Lab Manager:</b>	Geoff Benjamin	<b>Signature:</b>		<b>Date:</b>	07.03.2019

- Notes:**
1. Tests marked with \* are **NOT** UKAS accredited
  2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
  3. These results relate **ONLY** to the samples tested.
  4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
  5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.