

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

UKAS
TESTING
4564

REPORT NUMBER: 0006/22 ISSUE DATE: 04/02/2022

Sample type: Swimming Pool Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 31/01/2022

Sample receipt details: Date Received in Lab: 31/01/2022 Testing Date: 31/01/2022 – 03/02/2022

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
		Appearance	Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003 Enterococci
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	cfu/100ml
W006/1	Kingdom Hall Tank Levelwood	Clear	1.36	1.71	6	0	Not Detected	Not Detected	Not Detected
W006/2	Nr David Benjamin, Two Gun Saddle	Clear	1.32	1.61	0	0	Not Detected	Not Detected	Not Detected
W006/3	Nr Hay Town, Rupert's	Clear	2.06	2.31	0	0	Not Detected	Not Detected	Not Detected
W006/4	Spring Gut Tank	Clear	1.09	1.23	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayelo	Date:	03/02/2022
Checked by Quality Manager:	Toni Joshua	Signature:	Jishua	Date:	03/02/2022
Authorized by Ag Lab Manager:	Geoffrey Benjamin	Signature:	De	Date:	03/02/2022

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- ${\bf 2.\ Opinions\ and\ interpretations\ expressed\ herein\ are\ outside\ the\ scope\ of\ UKAS\ Accreditation.}$
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.