

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0008/22 ISSUE DATE: 11/02/22

4564

Sample type: Swimming Pool

Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 07/02/2022

Sample receipt details: Date Received in Lab: 07/02/2022

Testing Date: 08/02/2022 – 11/02/2022

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
		Appearance	Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003 Enterococci
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	cfu/100ml
W009/1	Contact Tank R Hill	Clear	2.96	3.27	0	0	Not Detected	Not Detected	Not Detected
W009/2	Nr Golf Course Longwood Hangings	Clear	1.11	1.29	0	0	Not Detected	Not Detected	Not Detected
W009/3	Nr Solomon's Shop Levelwood	Clear	1.37	1.62	6	0	Not Detected	Not Detected	Not Detected
W009/4	Briars Tank	Clear	1.14	1.29	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayoto	Date:	11/02/2022
Checked by Quality Manager:	Toni Joshua	Signature:	Fichia	Date:	11/02/2022
Authorized by Ag Lab Manager:	Geoffrey Benjamin	Signature:	Show	Date:	11/02/2022

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.