

Sample type: *Swimming Pool*

Mains – Chlorinated *Routine Control*

Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 07/03/2022

Sample receipt details: Date Received in Lab: 07/03/2022

Testing Date: 07/03/2022 – 10/03/2022

Mains – Untreated

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
		Appearance			* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003 Enterococci
			Free	Total	22ºC/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	cfu/100ml
W016/1	Kingdom Hall Tank Levelwood	Clear	1.04	1.18	17	78	Not Detected	Not Detected	Not Detected
W016/2	Nr David Benjamin Two Gun Saddle	Clear	1.36	1.54	2	0	Not Detected	Not Detected	Not Detected
W016/3	Nr Hay Town Ruperts	Clear	1.43	1.61	0	62	Not Detected	Not Detected	Not Detected
W016/4	Spring Gut Tank	Clear	1.07	1.21	>300	>300	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayeto	Date:	10/03/2022
Checked by Quality Manager:	Toni Joshua	Signature:	Ferma	Date:	10/03/2022
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:	But	Date:	10/03/2022

Notes:

1. Tests marked with * are NOT UKAS accredited

2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

3. These results relate **ONLY** to the samples as received and tested.

4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.

5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.