



**ST HELENA PUBLIC HEALTH LABORATORY**  
**General Hospital, Jamestown, St Helena**  
**Tel: +290 22500 Ext. 2035 Fax: +290 22530**  
**E-mail: microbiology @ sainthelena.gov.sh**

**WATER MICROBIOLOGY TEST REPORT**

**REPORT NUMBER: 0021/22**  
**ISSUE DATE: 01/04/22**



**Sample type:** *Swimming Pool*      *Routine Control*      *Mains – Chlorinated*      *Mains – Untreated*      *Other (Specify)*

**Sample collection details:** *Collected by: Darren Isaac*      *Name & Address of Customer: Connect St Helena, Seales Corner*      *Collection date: 28/03/2022*

**Sample receipt details:** *Date Received in Lab: 28/03/2022*      *Testing Date: 28/03/2022 – 31/03/2022*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003  <i>Enterococci</i> cfu/100ml
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	
W023/1	Bellstone Levelwood	Clear	1.24	1.39	0	0	Not Detected	Not Detected	Not Detected
W023/2	Nr Fox Garage Deadwood	Clear	1.04	1.29	0	3	Not Detected	Not Detected	Not Detected
W023/3	Nr Cleughs Plain Shop	Clear	1.07	1.34	9	36	Not Detected	Not Detected	Not Detected
W023/4	Nr Museum Jamestown	Clear	1.44	1.59	1	2	Not Detected	Not Detected	Not Detected

**KEY: cfu – colony forming units**

<b>Reported by Food Microbiologist:</b>	Kudzaiishe Nayoto	<b>Signature:</b>		<b>Date:</b>	31/03/2022
<b>Checked by Quality Manager:</b>	Toni Joshua	<b>Signature:</b>		<b>Date:</b>	31/03/2022
<b>Authorized by Lab Manager:</b>	Geoffrey Benjamin	<b>Signature:</b>		<b>Date:</b>	31/03/2022

**Notes:**

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples as received and tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.