

Sample type: Swimming Pool

Routine Control Mains – Chlorinated

<mark>rinated</mark>

Mains – Untreated

Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 25/04/2022

Sample receipt details: Date Received in Lab: 25/04/2022

Testing Date: 25/04/2022 – 28/04/2022

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
		Appearance			* WM 00 Total Colony cfu/1ml		WM 002		WM 003 Enterococci cfu/100ml
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	ciu/100mi
W032/1	Levelwood Contact Tank	Clear	2.75	2.98	0	0	Not Detected	Not Detected	Not Detected
W032/2	Nr Longwood Clinic	Clear	2.41	2.75	0	0	Not Detected	Not Detected	Not Detected
W032/3	Chubbs Spring Contact Tank	Clear	2.96	3.18	0	0	Not Detected	Not Detected	Not Detected
W032/4	Redhill Contact Tank	Clear	3.01	3.28	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayete	Date:	28/04/2022
Checked by Quality Manager:	Toni Joshua	Signature:	Joshua	Date:	28/04/2022
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:	liter	Date:	28/04/2022

Notes:

1. Tests marked with * are **NOT** UKAS accredited

2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

3. These results relate **ONLY** to the samples as received and tested.

4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.

5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.

Page 1 of 1