

## ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

## WATER MICROBIOLOGY TEST REPORT

UKAS
TESTING
4564

REPORT NUMBER: 0037/22 ISSUE DATE: 12/05/22

**Sample type:** Swimming Pool Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 09/05/2022

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
		Appearance	Free	Total	* WM 004 Total Colony Count cfu/1 ml		WM 002		WM 003  Enterococci
					22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	cfu/100ml
W035/1	Red Hill Levelwood Sheltered Accommodation	Clear	1.33	1.77	0	2	Not Detected	Not Detected	Not Detected
W035/2	Nr Reggie's Takeaway Bottom Woods	Clear	1.22	1.48	0	15	Not Detected	Not Detected	Not Detected
W035/3	Cow Path Tank	Clear	1.76	2.02	0	1	Not Detected	Not Detected	Not Detected
W035/4	Dillons Tank Jamestown	Clear	1.81	2.11	0	0	Not Detected	Not Detected	Not Detected

**KEY:** cfu – colony forming units

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayeto	Date:	12/05/2022
Checked by Quality Manager:	Toni Joshua	Signature:	Joshua	Date:	12/05/2022
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:	(Show	Date:	12/05/2022

## Notes:

- 1. Tests marked with \* are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.