

## ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

## WATER MICROBIOLOGY TEST REPORT

UKAS TESTING

**REPORT NUMBER: 0037/21** 

**Sample type:** Swimming Pool Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 12/04/2021

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
Lab 140.					* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml
W035/1	Three Tanks	Clear	1.07	1.19	1	4	Not Detected	Not Detected	Not Detected
W035/2	Nr. Levelwood Clinic	Clear	2.16	2.38	0	0	Not Detected	Not Detected	Not Detected
W035/3	Contact Tank Hutts Gate	Clear	3.16	3.42	0	0	Not Detected	Not Detected	Not Detected
W035/4	Playground Jamestown	Clear	2.08	2.19	0	0	Not Detected	Not Detected	Not Detected

## **KEY:** cfu – colony forming units

NE – Not examined

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KDayoto	Date:	19/04/2021
Checked by Quality Manager:	Keira Francis	Signature:	Herre	Date:	19/04/2021
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:	Dela	Date:	19/04/2021

## Notes:

- 1. Tests marked with \* are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.