

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

UKAS
TESTING
4564

REPORT NUMBER: 0074/22 ISSUE DATE: 08/09/2022

Sample type: Swimming Pool Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 05/09/2022

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results				
Lab No.	Source/Site	Appearance			* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml
W069/1	Nr Red Hill Levelwood Sheltered Accommodation	Clear	2.13	2.37	0	0	Not Detected	Not Detected	Not Detected
W069/2	Nr Reggie's Takeaway Bottom Woods	Clear	1.76	1.94	0	0	Not Detected	Not Detected	Not Detected
W069/3	Nr Playground Jamestown	Clear	1.26	1.39	0	1	Not Detected	Not Detected	Not Detected
W069/4	Cow Path Tank HTH	Clear	2.37	2.86	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

NE - Not examined

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	(K)ayoto	Date:	08/09/2022
Checked by Quality Manager:	Toni Joshua	Signature:	Fishing	Date:	08/09/2022
Authorized by Ag Lab Manager:	Wiseman Mbatha	Signature:	white has i	Date:	08/09/2022

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.