

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

UKAS
TESTING
4564

REPORT NUMBER: 0088/21 ISSUE DATE:10/09/21

Sample type: Swimming Pool Routine Control Mains – Chlorinated Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 06/09/2021

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
Lab 140.					* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	E.coli cfu/100 ml	Enterococci cfu/100ml
W085/1	Nr McDaniels Shop Cleughs Plain	Clear	2.54	2.69	0	0	Not Detected	Not Detected	Not Detected
W085/2	Nr Bellstone Levelwood	Clear	2.11	2.26	0	3	Not Detected	Not Detected	Not Detected
W085/3	Nr Fox's Garage Deadwood	Clear	1.96	2.12	0	0	Not Detected	Not Detected	Not Detected
W085/4	Nr Museum Jamestown	Clear	1.06	1.19	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

NE - Not examined

Reported by Food Microbiologist:	Kudzaiishe Nayoto	Signature:	KNayeto	Date:	10/09/2021
Checked by Ag Quality Manager:	Wiseman Mbatha	Signature:		Date:	10/09/2021
Authorized by Ag Lab Manager:	Wiseman Mbatha	Signature:	uthisatus	Date:	10/09/2021
			штьдени		

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.