

ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena Tel: +290 22500 Ext. 2035 Fax: +290 22530 E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

4564

REPORT NUMBER: 0115/21

ISSUE DATE: 16/12/21

Mains – Chlorinated Sample type: Swimming Pool Routine Control Mains – Untreated Other (Specify)

Sample collection details: Collected by: Darren Isaac Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 13/12/2021

Sample receipt details: Date Received in Lab: 13/12/2021 *Testing Date:* 13/12/2021 – 16/12/2021

Lab No.	Source/Site	* Macroscopic	* Cl. Levels (ppm)		Microbiology Results					
		Appearance			* WM 004 Total Colony Count cfu/1ml		WM 002		WM 003 Enterococci	
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	<i>E.coli</i> cfu/100 ml	cfu/100ml	
W109/1	Nr Levelwood Clinic	Clear	1.64	1.86	0	0	Not Detected	Not Detected	Not Detected	
W109/2	Hutts Gate Contact Tank	Clear	1.96	2.27	1	0	Not Detected	Not Detected	Not Detected	
W109/3	3 Tanks HTH	Clear	1.77	1.91	0	0	Not Detected	Not Detected	Not Detected	
W109/4	Dillons Tank, Jamestown	Clear	2.02	2.21	0	0	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units

Reported by Food Microbiologist:	Prince Magenga	Signature:		Date:	16/12/2021
Checked by Quality Manager:	Toni Joshua	Signature:	Joshua	Date:	16/12/2021
Authorized by Ag Lab Manager:	Geoffrey Benjamin	Signature:	(Show	Date:	16/12/2021

Notes:

- 1. Tests marked with * are NOT UKAS accredited
- 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
- 3. These results relate **ONLY** to the samples as received and tested.
- 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
- 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.