



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0081/20



4564

Other (Specify)

Mains – Untreated

Mains – Chlorinated

Routine Control

Collection date: 12/10/2020

Sample type: Swimming Pool Collected by: Darren Isaac

Name & Address of Customer: Connect St Helena, Seales Corner

Testing Date: 12/10/2020-15/10/2020

Sample receipt details: Date Received in Lab: 12/10/2020

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		* WM 004 Total Colony Count cfu/1ml				Microbiology Results		
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	E. coli cfu/100 ml	WM 003		
											Enterococci cfu/100ml
W0078/1	Nr Solomon's shop Levelwood	Clear	2.16	2.37	2	0	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected
W0078/2	Stand pipe Nr Golf course Longwood	Clear	2.21	2.33	0	0	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected
W0078/3	Standpipe Nr Sawmill Scotland	Clear	2.18	2.40	0	0	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected
W0078/4	Standpipe Nr Haytown Ruperts	Clear	1.23	1.56	11	5	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units
 NE – Not examined

Reported by Food Microbiologist:	Abraha Amanuel	Signature:		Date:	15/10/2020
Checked by Quality Manager:	Keira Francis	Signature:		Date:	15/10/2020
Authorized by Lab Manager:	Geoff Day	Signature:		Date:	15/10/2020

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples as received and tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.

Approved by Quality Manager 02/01/2020