



ST HELENA PUBLIC HEALTH LABORATORY

General Hospital, Jamestown, St Helena
Tel: +290 22500 Ext. 2035 Fax: +290 22530
E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0071/20



Sample type: *Swimming Pool* Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: Collected by: Darren Isaac

Name & Address of Customer: Connect St Helena, Seales Corner

Collection date: 07/09/2020

Sample receipt details: Date Received in Lab: 07/09/2020

Testing Date: 07/09/2020-10/09/2020

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		* WM 004 Total Colony Count cfu/ml			Microbiology Results		
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	WM 002 E.coli cfu/100 ml	WM 003 Enterococci cfu/100ml	
W0068/1	Contact Tank Red Hill	Clear	2.30	2.52	0	0	Not Detected	Not Detected	Not Detected	
W0068/2	Standpipe Nr. Playground Half Tree Hollow	Clear	1.52	1.78	0	0	Not Detected	Not Detected	Not Detected	
W0068/3	Standpipe Nr. Longwood Clinic	Clear	2.02	2.29	0	0	Not Detected	Not Detected	Not Detected	
W0068/4	Contact Tank Chubb's Spring	Clear	1.95	2.31	0	0	Not Detected	Not Detected	Not Detected	

KEY: cfu – colony forming units
NE – Not examined

Reported by Ag. Food Microbiologist:	Helena Stevens	Signature:		Date:	10/09/2020
Checked by Quality Manager:	Keira Francis	Signature:		Date:	10/09/2020
Authorized by Ag. Lab Manager:	Steve Dwyer	Signature:		Date:	10/09/2020

- Notes:
1. Tests marked with * are NOT UKAS accredited
 2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
 3. These results relate ONLY to the samples as received and tested.
 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.