



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



4564

Sample type: *Swimming Pool*

Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: *Collected by: Brian Young Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 18/11/2019*

Sample receipt details: *Date Received in Lab: 18/11/2019*

Testing Date: 19/11/2019

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* W/M 004 Total Colony Count cfu/1ml	W/M 002 Coliforms cfu/100 ml	W/M 003 <i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml	
W1014/1	Standpipe Bellstone Levelwood	Clear	2.66	2.83	0	>300	Not Detected	Not Detected	Not Detected
W1014/2	Stand pipe Fox Garage Deadwood	Clear	2.64	2.79	0	0	Not Detected	Not Detected	Not Detected
W1014/3	Standpipe McDaniel's Shop Cleughs Plain	Clear	1.25	1.56	>300	>300	Not Detected	Not Detected	Not Detected
W1014/4	Standpipe Jamestown Nr Museum	Clear	3.20	3.56	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units
NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	25/11/19
Checked by Trainee Quality Manager:	Keira Francis	Signature:		Date:	25/11/19
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:		Date:	25/11/19

Notes:

1. Tests marked with * are NOT UKAS accredited
2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
3. These results relate **ONLY** to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.