



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: [microbiology@sainthelena.gov.sh](mailto:microbiology@sainthelena.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



Sample type: *Swimming Pool*

*Routine Control*

**Mains – Chlorinated**

*Mains – Untreated*

*Other (Specify)*

Sample collection details: *Collected by: Brian Young Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 09/12/2019*

Sample receipt details: *Date Received in Lab: 09/12/2019*

*Testing Date: 09/12/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* W/M 004 Total Colony Count cfu/1ml	W/M 002 Coliforms cfu/100 ml	W/M 003 <i>E.coli</i> cfu/100 ml	<i>Enterococci</i> cfu/100ml	
W1022/1	Standpipe Solomon Shop Levelwood	Clear	1.25	1.50	6	1	Not Detected	Not Detected	Not Detected
W1022/2	Standpipe Golf Course Longwood	Clear	1.49	1.77	0	0	Not Detected	Not Detected	Not Detected
W1022/3	Standpipe Longwood Clinic	Clear	1.86	2.10	0	0	Not Detected	Not Detected	Not Detected
W1022/4	Standpipe Nr Saw Mill	Clear	1.62	1.88	>300	>300	Not Detected	Not Detected	Not Detected
W1022/5	Contact Tank Red Hill	Clear	2.19	2.40	2	3	Not Detected	Not Detected	Not Detected
W1022/6	Standpipe HTH Playground	Clear	1.26	1.52	>300	>300	Not Detected	Not Detected	Not Detected
W1022/7	Standpipe Briars Tank	Clear	2.10	2.31	0	0	Not Detected	Not Detected	Not Detected
W1022/8	Contact Tank Chubb's Spring	Clear	2.62	2.88	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	12/12/19
Checked by Trainee Quality Manager:	Keira Francis	Signature:		Date:	12/12/19
Authorized by Ag Lab Manager:	Wiseman Mbattha	Signature:		Date:	12/12/19

Notes:

1. Tests marked with \* are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.