



**ST HELENA PUBLIC HEALTH LABORATORY**  
 General Hospital, Jamestown, St Helena  
 Tel: +290 22500 Ext. 2035 Fax: +290 22530  
 E-mail: [microbiology@sainthelena.gov.sh](mailto:microbiology@sainthelena.gov.sh)

**WATER MICROBIOLOGY TEST REPORT**



Sample type: *Swimming Pool*      Routine Control      **Mains – Chlorinated**      Mains – Untreated      Other (Specify)

Sample collection details: *Collected by: Brian Young*      Name & Address of Customer: *Connect St Helena, Seales Corner*      Collection date: *16/12/2019*

Sample receipt details: *Date Received in Lab: 16/12/2019*      Testing Date: *16/12/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		* W/M 004 Total Colony Count cfu/1ml			Microbiology Results		
			Free	Total	22°C/72h	37°C/48h	Coliforms cfu/100 ml	E. coli cfu/100 ml	W/M 002	W/M 003
W/1025/1	Standpipe Bellstone Levelwood	Clear	2.20	2.33	21	106	Not Detected	Not Detected	Not Detected	Not Detected
W/1025/2	Standpipe Fox Garage	Clear	2.06	2.29	0	0	Not Detected	Not Detected	Not Detected	Not Detected
W/1025/3	Standpipe Cleugh's Plain	Clear	1.30	1.46	>300	>300	Not Detected	Not Detected	Not Detected	Not Detected
W/1025/4	Standpipe Museum Jamestown	Clear	2.69	2.81	0	0	Not Detected	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units  
 NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	19/12/19
Checked by Trainee Quality Manager:	Keira Francis	Signature:		Date:	19/12/19
Authorized by Ag Lab Manager:	Wiseman Mbatha	Signature:		Date:	19/12/19

- Notes:
1. Tests marked with \* are NOT UKAS accredited
  2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
  3. These results relate ONLY to the samples tested.
  4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
  5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.