



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: *Swimming Pool* *Routine Control* *Mains – Chlorinated* *Mains – Untreated* *Other (Specify)*

Sample collection details: *Collected by: Colin Peters* *Name & Address of Customer: Connect St Helena, Seales* *Corner Collection date: 22/07/2019*

Sample receipt details: *Date Received in Lab: 22/07/2019* *Testing Date: 22/07/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results			
			22°C/72h	37°C/48h	WM 002	WM 003		
W/981/1	Cow Path Tank H.T.H.	Clear	1.11	1.27	0	0	Not Detected	Not Detected
W/981/2	Standpipe Nr. Sheltered Acc. Red Hill Levelwood	Clear	2.42	2.56	0	0	Not Detected	Not Detected
W/981/3	Standpipe Nr Reggie's Takeaways Bottom Woods	Clear	2.60	2.78	0	0	Not Detected	Not Detected
W/981/4	Standpipe Playground Jamestown	Clear	2.00	2.16	16	0	Not Detected	Not Detected

KEY: cfu – colony forming units
 NE – Not examined

Reported by: Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	25/07/19
Checked by Ag. Quality Manager:	Geoff Benjamin	Signature:		Date:	25/07/19
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	25/07/19

- Notes:
1. Tests marked with * are NOT UKAS accredited
 2. **Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.**
 3. These results relate ONLY to the samples tested.
 4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
 5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.