



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: *Swimming Pool*

Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: *Collected by: Colin Peters Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 05/08/2019*

Sample receipt details: *Date Received in Lab: 05/08/2019*

Testing Date: 05/08/2019

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results			
			Free	Total	* WM 004 Total Colony Count cfu/1ml	WM 002	WM 003	
W985/1	Standpipe Spring Gut	Clear	1.03	1.32	0	0	Not Detected	Not Detected
W985/2	Contact Tank Levelwood	Clear	2.36	2.48	0	296	Not Detected	Not Detected
W985/3	Standpipe Nr. David Benjamin's Two Gun Saddle	Clear	2.43	2.63	0	0	Not Detected	Not Detected
W985/4	Standpipe Nr Haytown Ruperts	Clear	1.80	1.98	0	0	Not Detected	Not Detected

KEY: cfu – colony forming units

NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	09/08/19
Checked by Ag. Quality Manager:	Geoff Benjamin	Signature:		Date:	09/08/19
Authorized by Ag. Lab Manager:	Geoff Benjamin	Signature:		Date:	09/08/19

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.