



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



Sample type: *Swimming Pool* Routine Control **Mains – Chlorinated** Mains – Untreated Other (Specify)

Sample collection details: *Collected by: Colin Peters* Name & Address of Customer: *Connect St Helena, Seales Corner* Collection date: *12/08/2019*

Sample receipt details: *Date Received in Lab: 12/08/2019* Testing Date: *12/08/2019*

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* W/M 004 Total Colony Count cfu/ml		W/M 002	W/M 003	
					22°C/72h	37°C/48h			Coliforms cfu/100 ml
W986/1	Standpipe Nr. Sawmill Scotland	Clear	1.05	1.38	0	0	Not Detected	Not Detected	Not Detected
W986/2	Standpipe Nr Solomon's Shop Levelwood	Clear	2.15	2.38	0	0	Not Detected	Not Detected	Not Detected
W986/3	Standpipe Nr Golf Course Longwood	Clear	2.88	3.02	0	0	Not Detected	Not Detected	Not Detected
W986/4	Standpipe Briars Tank	Clear	2.26	2.41	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	15/08/19
Checked by Quality Manager:	Helena Stevens	Signature:		Date:	15/08/19
Authorized by Lab Manager:	Geoff Benjamin	Signature:		Date:	15/08/19

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.