



ST HELENA PUBLIC HEALTH LABORATORY
 General Hospital, Jamestown, St Helena
 Tel: +290 22500 Ext. 2035 Fax: +290 22530
 E-mail: microbiology@sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT



4564

Sample type: *Swimming Pool*

Routine Control

Mains – Chlorinated

Mains – Untreated

Other (Specify)

Sample collection details: *Collected by: Brian Young Name & Address of Customer: Connect St Helena, Seales Corner Collection date: 16/09/2019*

Sample receipt details: *Date Received in Lab: 16/09/2019*

Testing Date: 16/09/2019

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
			Free	Total	* WM 004 Total Colony Count cfu/1ml		WM 002	WM 003	
					22°C/72h	37°C/48h			Coliforms cfu/100 ml
W992/1	Standpipe Levelwood Clinic	Clear	1.62	1.93	1	0	Not Detected	Not Detected	Not Detected
W992/2	Standpipe Hutt's Gate	Clear	2.90	3.22	0	0	Not Detected	Not Detected	Not Detected
W992/3	Standpipe Three Tanks	Clear	1.25	1.50	0	0	Not Detected	Not Detected	Not Detected
W992/4	Standpipe Dillon's Tank Jamestown	Clear	2.70	2.87	0	0	Not Detected	Not Detected	Not Detected

KEY: cfu – colony forming units

NE – Not examined

Reported by Food Microbiologist:	Kudzaishe Nayoto	Signature:		Date:	19/09/19
Checked by Quality Manager:	Helena Stevens	Signature:		Date:	19/09/19
Authorized by Lab Manager:	Geoffrey Benjamin	Signature:		Date:	19/09/19

Notes:

1. Tests marked with * are NOT UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate ONLY to the samples tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.